



Compliance Statement

ISO/IEC, EN & TIA Unscreened Class E / Category 6 Dintek Four Connector Channel

Dintek Electronic Ltd.
No. 8, Lane 97, Wu -Kong Rd., Wu-Ku Industrial District,
Hsin Chuang, Taipei Hsien, Taiwan, R.O.C.

Compliance Statement No. 112724

This type of Class E / Category 6 unscreened four connector channel has been tested by 3P Third Party Testing and complies with the Class E requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6 requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the channel type in T568B designation and may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 12 month intervals. The channel consists of the following Dintek components:

<i>Cables:</i>	<i>Horizontal Cable,</i>	<i>P/N 1101-040XX (with PVC sheath)</i>
	<i>Flexible Cable,</i>	<i>From Patch Cords, P/N 1201-04XXX (with PVC sheath)</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jack,</i>	<i>P/N 1305-040XX</i>
		<i>having PCB marking LE000495-A1-ROHS</i>
	<i>Patch Panel,</i>	<i>P/N 1402-040XX</i>
		<i>having PCB marking LE000422 A3-ROHS</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Patch Cords:</i>	<i>3 m,5 m,</i>	<i>P/N 1201-04XXX</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Consolidation Cord:</i>	<i>2 m,</i>	<i>From Patch Cord, P/N 1201-04XXX</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 2nd October 2012

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 2nd October 2012

Paul Villien

Poul Villien
Coordinating Manager