



Compliance Statement

Unscreened Class EA / Category 6A ISO/IEC, EN & ANSI/TIA Two Connector Channel

Dintek Electronic Ltd.
5F, No.9, Ln.3, Minsheng W. Rd., Zhongshan Dist.,
10449 Taipei City, Taiwan R.O.C.

Compliance Statement No. 0473-3P-1231098

This type of Class EA / Category 6A Unscreened Two Connector Channel has been tested by 3P Third Party Testing. The testing has shown compliance with the Class EA electrical performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, edition 1.0 of ISO/IEC 11801-2:2017, CENELEC EN 50173-1:2018 and the Category 6A electrical performance requirements of ANSI/TIA-568.2-D:2018. The Compliance Statement is valid for the actually tested channel samples, consisting of the listed components. The tested channel is part of a 3P maintenance programme, with continuous verification of the electrical performance. The Compliance Statement is valid until 28 August 2026.

Cables:	<i>Horizontal Cable (90 m), Qualification Status:</i>	<i>P/N 1101-06XXX: Cat.6A U/UTP LSZH cable Manufacturer verified</i>
Conn. Hardware:	<i>Modular Jack, Qualification Status:</i>	<i>P/N 1305-05XXX: Cat.6A Unshielded keystone jack Manufacturer verified</i>
Patch and equipment Cords:	<i>5 m, Qualification Status:</i>	<i>P/N 1201-06XXX: Cat.6A F/UTP LSZH patch cord Manufacturer verified</i>

Hoersholm, 28 February 2024


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 28 February 2024


Jens Rytter Petersen
General Manager